



Notes.

1. If applicable, the joint filler should be specified to have the same fire resistance as the blockwork.
2. The joint between the blockwork and the concrete slab is typically 10-12mm but can be increased if a greater deflection is anticipated

REV.	DATE.	DESCRIPTION.	BY.

These details have been produced for guidance only. It is the responsibility of the building designer to ensure that the details shown are compatible with the overall building design and will satisfy the relevant parts of the Building Regulations applicable before they are adopted into the project design.

LIGNACITE
Concrete Masonry Products

Lignacite Ltd
Norfolk House, High St
Brandon, Suffolk IP27 0AX.

Tel : +44 (0)1842 810678
Fax : +44 (0)1842 814602
E-mail : info@lignacite.co.uk

Concrete Blockwork		
Head Restraint to a Concrete Floor using Angle Supports, allowing for Vertical Deflection		
DWG No.	TDS/10	
DRAWN BY	PTS	CHECKED BY C.M.
DATE	SCALE	REV.NO.
June 2016	1:5 @ A4	