



Notes.

1. If applicable, the joint filler should be specified to have the same fire resistance as the blockwork.
2. Movement joints are normally built to a 10mm nominal width.
3. Clearance between the blockwork and steel column should be allowed for to cater for steelwork movement.

REV.	DATE.	DESCRIPTION.	BY.

These details have been produced for guidance only. It is the responsibility of the building designer to ensure that the details shown are compatible with the overall building design and will satisfy the relevant parts of the Building Regulations applicable before they are adopted into the project design.

LIGNACITE
Concrete Masonry Products

Lignacite Ltd
Norfolk House, High St
Brandon, Suffolk IP27 0AX.
Tel : +44 (0)1842 810678
Fax : +44 (0)1842 814602
E-mail : info@lignacite.co.uk

Concrete Blockwork

Blockwork abutting a steel column

DWG No. TDS/14

DRAWN BY PTS CHECKED BY C.M.

DATE June 2016 SCALE 1:4 @ A4 REV.NO.