



Notes.

1. Bed joint reinforcement is intended to replace the flexural resistance that is parallel to the bed joints, which is present in stretcher bond masonry, but absent when units are laid stack bonded.
2. Bed joint reinforcement will also help with crack control.
3. The minimum cover to reinforcement specified in BS 5628-2 is 15 mm, but it is normal practice to use 20 mm.

REV.	DATE.	DESCRIPTION.	BY.

These details have been produced for guidance only. It is the responsibility of the building designer to ensure that the details shown are compatible with the overall building design and will satisfy the relevant parts of the Building Regulations applicable before they are adopted into the project design.

LIGNACITE
Concrete Masonry Products

Lignacite Ltd
Norfolk House, High St
Brandon, Suffolk IP27 0AX.
Tel : +44 (0)1842 810678
Fax : +44 (0)1842 814602
E-mail : info@lignacite.co.uk

Concrete Blockwork

Reinforcing Stack Bonded Masonry

DWG No. TDS/15

DRAWN BY PTS CHECKED BY C.M.

DATE June 2016 SCALE N.T.S. REV.NO.